SE MINNESOTA WATER ANALYSIS LABORATORY
2100 CAMPUS DR SE
ROCHESTER, MN 55904-4722
PHONE: (507) 328-7495
FAX: (507) 328-7485
EMAIL: waterlab@co.olmsted.mn.us

Report Date:	**10/23/2026**
Lab Number:	**55091**
Received Date:	**10/21/2026**
Received Time:	**10:37**
Sampled Date:	**10/21/2026**
Sampled Time:	**9:15**
Sampler:	**JOE FLETT**
Sampler Title:	**ENV. PR. MANAGER**
Unique Number:	**0000132658**
Temp(C)@ receipt:	**15.5~**

SUSAN KREIDERMACHER
22908 COUNTY HWY 34
KASSON, MN 55944

Sample Name: **SUSAN KREIDERMACHER**
Sample Location: **22908 COUNTY HWY 34 KASSON MN 55944**
Reason For Test: **FINANCING / SALE**
Comments: **Bacteria Prep Date/Time: 10/21/26 1110 This sample meets EPA primary drinking water standards for all of the analytes tested.**

Analyte	Result	Method	(LRL*)	Prep^/Analyzed	Analyst
Chloride	**21.5 mg/L**	EPA 300.0 Rev 2.1	(1 mg/L)	10/21/26 15:10	oc10994
Fluoride	**0.2 mg/L**	EPA 300.0 Rev 2.1	(0.2 mg/L)	10/21/26 15:10	oc10994
Nitrate	**< 0.5 mg/L**	EPA 300.0 Rev 2.1	(0.5 mg/L)	10/21/26 15:10	oc10994
Nitrite	**< 0.1 mg/L**	EPA 300.0 Rev 2.1	(0.1 mg/L)	10/21/26 15:10	oc10994
Sulfate	**37.9 mg/L**	EPA 300.0 Rev 2.1	(0.5 mg/L)	10/21/26 15:10	oc10994
E. coli	**Absent**	SM 9223 B	(1 colony / 100 ml)	10/23/26 8:00	SJ
Total Coliform	**Absent**	SM 9223 B	(1 colony / 100 ml)	10/23/26 8:00	SJ

Digitally signed by MORGAN REESE
Date: 2026.10.23 10:48:12 -05'00'

Lab Analyst or Lab Manager

Laboratory Certification: MN LAB # 027-109-399 EPA LAB CODE MN00096
SEMWAL is accredited by the Minnesota Department of Health
Environmental Laboratory Accreditation Program and conforms to current TNI standards.
** = See 'Meaning of Test Results' fact sheet for additional information.
(LRL*) = Laboratory Reporting Limit is the lowest value of the analyte that can be quantitatively determined.
~ = Sample received outside temperature range specified in Minnesota statutes.
EX = Sample received outside holding time specified in EPA 300.0 Rev. 2.1
^ = Date and time chemistry sample was prepared for analysis. For bacteria see Comments